

4. 処理実績

(1) 水処理実績

| 単位 | 全放流量 | | | | | | | | | | | | 合計 m ³ |
|-----|-----------------------------|-----------------------------|-----------------------|-----------------------|-------------------------|-------------------------|--------------------------------|-------------------------------|-----------------------|----------------------|------------|------------|----------------------|
| | 雨水系放流量 | | 污水系放流量 | | | | | | | | 合計 | | |
| | 雨水 放流量 m ³ | 一次 放流量 m ³ | 二次放流量 | | | | ピオトーブ 送水量 m ³ | 民間工場 送水量 m ³ | その他 m ³ | 合計 m ³ | | | |
| | | | 日平均 m ³ | 日最大 m ³ | 晴天日平均 m ³ | 晴天日最大 m ³ | | | | | | | |
| 4月 | 402,515 | 430,920 | 4,300,863 | 143,362 | 197,793 | 123,416 | 134,652 | 14,525 | 0 | 559 | 4,315,947 | 5,149,382 | |
| 5月 | 205,230 | 243,680 | 4,262,154 | 137,489 | 177,247 | 123,207 | 135,120 | 12,594 | 0 | 529 | 4,275,277 | 4,724,187 | |
| 6月 | 613,534 | 758,250 | 4,524,550 | 150,818 | 230,015 | 123,623 | 167,947 | 12,733 | 0 | 543 | 4,537,826 | 5,909,610 | |
| 7月 | 343,751 | 421,530 | 4,842,140 | 156,198 | 205,358 | 129,786 | 152,852 | 13,403 | 0 | 667 | 4,856,210 | 5,621,491 | |
| 8月 | 96,379 | 79,580 | 3,628,955 | 117,063 | 179,250 | 112,813 | 127,774 | 13,589 | 0 | 792 | 3,643,336 | 3,819,295 | |
| 9月 | 664,158 | 737,980 | 4,342,635 | 144,755 | 207,295 | 112,602 | 127,002 | 12,429 | 0 | 495 | 4,355,559 | 5,757,697 | |
| 10月 | 191,886 | 213,250 | 4,384,402 | 141,432 | 187,342 | 130,256 | 148,326 | 12,429 | 0 | 478 | 4,397,309 | 4,802,445 | |
| 11月 | 110,238 | 226,380 | 3,866,022 | 128,867 | 172,233 | 109,828 | 116,085 | 12,998 | 0 | 474 | 3,879,494 | 4,216,112 | |
| 12月 | 149,264 | 312,180 | 4,078,737 | 131,572 | 190,698 | 113,260 | 124,184 | 14,698 | 0 | 223 | 4,093,658 | 4,555,102 | |
| 1月 | 74,424 | 135,740 | 3,735,909 | 120,513 | 178,083 | 111,570 | 121,167 | 11,855 | 0 | 431 | 3,748,195 | 3,958,359 | |
| 2月 | 58,384 | 115,720 | 3,303,941 | 117,998 | 159,147 | 107,309 | 113,469 | 12,453 | 0 | 1,020 | 3,317,414 | 3,491,518 | |
| 3月 | 54,792 | 151,040 | 3,419,935 | 110,320 | 144,005 | 98,531 | 105,384 | 14,207 | 0 | 474 | 3,434,616 | 3,640,448 | |
| 年合計 | 2,964,555 | 3,826,250 | 48,690,243 | | | | | 157,913 | 0 | 6,685 | 48,854,841 | 55,645,646 | |
| 月平均 | 247,046 | 318,854 | 4,057,520 | | 年間最大 | 年間平均 | 年間最大 | 13,159 | 0 | 557 | 4,071,237 | 4,637,137 | |
| 日平均 | 8,122 | 10,483 | 133,398 | | 230,015 | 116,001 | 167,947 | 433 | 0 | 18 | 133,849 | 152,454 | |

| 単位 | 降雨量 mm | (場内循環水含む) | | | | | | | | | |
|-----|-----------|-----------------------|-----------------------|-----------------------|--------------------------------|-------------------------|-------------------------|-----------------------|-----------------------|-----------------------|---------|
| | | 流入水量 | | | 雨水ポンプ 放出量 m ³ | 一次処理量 m ³ | 二次処理量 m ³ | 晴天時処理量 | | | |
| | | 日平均 m ³ | 日最大 m ³ | 日平均 m ³ | | | | 日最大 m ³ | 日平均 m ³ | 日最大 m ³ | |
| 4月 | 249.0 | 4,936,020 | 164,534 | 291,160 | 402,515 | 430,920 | 4,505,100 | 150,170 | 198,800 | 131,960 | 142,100 |
| 5月 | 154.5 | 4,730,480 | 152,596 | 243,020 | 205,230 | 243,680 | 4,486,800 | 144,735 | 182,600 | 131,950 | 142,300 |
| 6月 | 351.0 | 5,454,150 | 181,805 | 405,440 | 613,534 | 758,250 | 4,695,900 | 156,530 | 229,000 | 131,925 | 170,900 |
| 7月 | 237.0 | 5,373,630 | 173,343 | 331,560 | 343,751 | 421,530 | 4,952,100 | 159,745 | 204,600 | 132,962 | 148,900 |
| 8月 | 80.0 | 3,937,080 | 127,003 | 247,490 | 96,379 | 79,580 | 3,857,500 | 124,435 | 186,800 | 119,754 | 127,000 |
| 9月 | 383.5 | 5,306,580 | 176,886 | 360,270 | 664,158 | 737,980 | 4,568,600 | 152,287 | 212,700 | 122,060 | 135,700 |
| 10月 | 123.5 | 4,816,250 | 155,363 | 289,640 | 191,886 | 213,250 | 4,603,000 | 148,484 | 192,200 | 137,986 | 153,600 |
| 11月 | 110.0 | 4,150,680 | 138,356 | 231,570 | 110,238 | 226,380 | 3,924,300 | 130,810 | 171,100 | 112,983 | 119,300 |
| 12月 | 121.5 | 4,445,280 | 143,396 | 278,580 | 149,264 | 312,180 | 4,133,100 | 133,326 | 195,600 | 116,125 | 127,000 |
| 1月 | 69.5 | 3,953,340 | 127,527 | 199,300 | 74,424 | 135,740 | 3,817,600 | 123,148 | 179,500 | 114,831 | 123,800 |
| 2月 | 55.0 | 3,504,720 | 125,169 | 206,360 | 58,384 | 115,720 | 3,389,000 | 121,036 | 158,000 | 112,414 | 116,800 |
| 3月 | 66.0 | 3,670,140 | 118,392 | 201,490 | 54,792 | 151,040 | 3,519,100 | 113,519 | 148,600 | 103,140 | 109,000 |
| 年合計 | 2,000.5 | 54,278,350 | | | 2,964,555 | 3,826,250 | 50,452,100 | | | | |
| 月平均 | 166.7 | 4,523,196 | | 年間最大 | 247,046 | 318,854 | 4,204,342 | | 年間最大 | 年間平均 | 年間最大 |
| 日平均 | 5.5 | 148,708 | | 405,440 | 8,122 | 10,483 | 138,225 | | 229,000 | 121,846 | 170,900 |

| 単位 | 沈砂池 | | 最初沈殿池 | | エアレーションタンク | | | | | 最終沈殿池 | | 消毒槽 | | |
|-----|--------|-------|----------------|------|----------------|------|------|----------------|-------|----------------|-------|------|----------|------|
| | し渣 | 沈砂 | 生汚泥量 | 沈殿時間 | 曝気風量 | | 曝気時間 | 返送汚泥 | | 余剰汚泥量 | | 沈殿時間 | 次亜使用量 | |
| | | | | | ×1,000 | 倍率 | | 返送率 | 発生率 | (塩素換算) | 塩素注入率 | | | |
| | t | t | m ³ | h | m ³ | 倍 | h | m ³ | % | m ³ | % | h | kg | mg/l |
| 4月 | 33.38 | 1.50 | 71,455 | 4.59 | 15,018 | 3.44 | 7.31 | 1,728,900 | 39.25 | 43,041 | 0.98 | 4.75 | 5,779.1 | 1.22 |
| 5月 | 27.62 | 1.00 | 66,512 | 4.81 | 15,753 | 3.56 | 7.50 | 1,787,200 | 40.27 | 37,103 | 0.84 | 4.87 | 5,106.2 | 1.13 |
| 6月 | 32.73 | 2.50 | 70,457 | 4.34 | 13,882 | 3.11 | 7.08 | 1,723,400 | 37.91 | 34,638 | 0.76 | 4.61 | 7,039.2 | 1.33 |
| 7月 | 18.13 | 4.00 | 68,221 | 4.40 | 14,549 | 3.02 | 6.91 | 1,785,600 | 37.03 | 31,076 | 0.64 | 4.25 | 5,674.8 | 1.08 |
| 8月 | 17.52 | 1.00 | 66,841 | 5.73 | 15,063 | 3.95 | 8.72 | 1,781,500 | 46.69 | 40,165 | 1.05 | 5.33 | 3,648.8 | 0.98 |
| 9月 | 20.45 | 1.20 | 65,705 | 4.67 | 13,764 | 3.16 | 7.29 | 1,726,500 | 39.13 | 31,419 | 0.72 | 4.44 | 6,812.2 | 1.34 |
| 10月 | 17.27 | 3.50 | 66,377 | 5.21 | 15,431 | 3.44 | 7.35 | 1,778,500 | 39.30 | 27,098 | 0.60 | 4.50 | 5,439.2 | 1.18 |
| 11月 | 31.65 | 1.20 | 73,830 | 5.86 | 15,567 | 4.05 | 8.34 | 1,711,100 | 44.37 | 30,302 | 0.79 | 5.07 | 4,564.9 | 1.12 |
| 12月 | 33.99 | 3.00 | 69,674 | 5.76 | 15,829 | 3.94 | 8.23 | 1,786,300 | 44.18 | 34,143 | 0.84 | 5.03 | 5,050.4 | 1.15 |
| 1月 | 21.49 | 3.00 | 65,745 | 6.27 | 16,749 | 4.45 | 8.83 | 1,786,400 | 47.38 | 33,144 | 0.88 | 5.40 | 4,006.9 | 1.03 |
| 2月 | 19.84 | 0.00 | 59,598 | 6.38 | 15,071 | 4.49 | 8.95 | 1,614,400 | 48.10 | 33,220 | 0.99 | 5.48 | 3,440.1 | 1.01 |
| 3月 | 22.53 | 0.00 | 62,674 | 6.80 | 17,298 | 4.99 | 9.59 | 1,771,900 | 51.08 | 42,171 | 1.22 | 5.96 | 3,797.3 | 1.06 |
| 年合計 | 296.60 | 21.90 | 807,089 | | 183,974 | | | 20,981,700 | | 417,520 | | | 60,359.1 | |
| 月平均 | 24.72 | 1.83 | 67,257 | 5.40 | 15,331 | 3.80 | 8.01 | 1,748,475 | 42.89 | 34,793 | 0.86 | 4.97 | 5,029.9 | 1.14 |
| 日平均 | 0.81 | 0.06 | 2,211 | | 504 | | | 57,484 | | 1,144 | | | 165.4 | |

第一処理施設

| 単位 | 処理水量 | | 最初沈殿池 | | エアレーションタンク | | | | | 最終沈殿池 | | 消毒槽 | | |
|-----|----------------|----------------|----------------|------|----------------|------|-------|----------------|-------|----------------|-------|------|----------|------|
| | 一次処理量 | 二次処理量 | 生汚泥量 | 沈殿時間 | 曝気風量 | | 曝気時間 | 返送汚泥 | | 余剰汚泥量 | | 沈殿時間 | 次亜使用量 | |
| | | | | | ×1,000 | 倍率 | | 返送率 | 発生率 | (塩素換算) | 塩素注入率 | | | |
| | m ³ | m ³ | m ³ | h | m ³ | 倍 | h | m ³ | % | m ³ | % | h | kg | mg/l |
| 4月 | 428,920 | 1,478,700 | 40,830 | 5.50 | 3,315 | 2.30 | 7.62 | 518,300 | 35.70 | 10,221 | 0.71 | 5.21 | 3,127.2 | 1.84 |
| 5月 | 243,680 | 1,475,800 | 36,260 | 5.85 | 3,424 | 2.35 | 7.82 | 535,600 | 36.65 | 7,685 | 0.53 | 5.34 | 2,503.9 | 1.66 |
| 6月 | 758,050 | 1,520,400 | 40,670 | 5.11 | 3,152 | 2.17 | 7.49 | 516,700 | 35.00 | 9,170 | 0.61 | 5.12 | 4,246.5 | 2.04 |
| 7月 | 421,430 | 1,614,900 | 38,010 | 5.35 | 3,431 | 2.19 | 7.23 | 535,600 | 33.90 | 10,099 | 0.63 | 4.24 | 2,641.2 | 1.45 |
| 8月 | 79,580 | 1,294,500 | 36,280 | 7.05 | 3,546 | 2.77 | 8.90 | 532,400 | 41.45 | 10,639 | 0.83 | 5.07 | 1,371.4 | 1.16 |
| 9月 | 737,780 | 1,499,300 | 35,990 | 5.19 | 3,216 | 2.24 | 7.60 | 518,400 | 35.63 | 9,686 | 0.67 | 4.33 | 3,849.5 | 1.91 |
| 10月 | 213,250 | 1,480,700 | 34,680 | 6.02 | 3,472 | 2.41 | 7.90 | 533,200 | 36.88 | 6,054 | 0.41 | 4.50 | 2,396.1 | 1.60 |
| 11月 | 226,380 | 1,163,300 | 39,600 | 7.16 | 3,333 | 2.92 | 9.65 | 512,900 | 44.75 | 4,727 | 0.41 | 5.50 | 2,205.4 | 1.62 |
| 12月 | 311,780 | 1,221,800 | 37,810 | 7.21 | 3,464 | 2.95 | 9.64 | 535,700 | 45.21 | 8,659 | 0.73 | 5.49 | 2,528.0 | 1.70 |
| 1月 | 135,740 | 1,134,200 | 33,040 | 7.89 | 3,479 | 3.13 | 10.25 | 535,600 | 48.05 | 6,740 | 0.60 | 5.84 | 1,729.5 | 1.41 |
| 2月 | 115,720 | 1,015,600 | 31,440 | 7.97 | 3,178 | 3.18 | 10.31 | 483,800 | 48.34 | 7,998 | 0.80 | 5.88 | 1,443.0 | 1.32 |
| 3月 | 151,040 | 1,097,400 | 31,460 | 8.13 | 3,510 | 3.27 | 10.62 | 527,100 | 48.91 | 9,825 | 0.91 | 6.34 | 1,771.8 | 1.49 |
| 年合計 | 3,823,350 | 15,996,600 | 436,070 | | 40,520 | | | 6,285,300 | | 101,503 | | | 29,813.5 | |
| 月平均 | 318,613 | 1,333,050 | 36,339 | 6.54 | 3,377 | 2.66 | 8.75 | 523,775 | 40.87 | 8,459 | 0.65 | 5.24 | 2,484.5 | 1.60 |
| 日平均 | 10,475 | 43,826 | 1,195 | | 111 | | | 17,220 | | 278 | | | 81.7 | |

第二処理施設

| 単位 | 処理水量 | | 最初沈殿池 | | エアレーションタンク | | | | | 最終沈殿池 | | 消毒槽 | | |
|-----|----------------|----------------|----------------|------|----------------|------|------|----------------|-------|----------------|-------|------|----------|------|
| | 一次処理量 | 二次処理量 | 生汚泥量 | 沈殿時間 | 曝気風量 | | 曝気時間 | 返送汚泥 | | 余剰汚泥量 | | 沈殿時間 | 次亜使用量 | |
| | | | | | ×1,000 | 倍率 | | 返送率 | 発生率 | (塩素換算) | 塩素注入率 | | | |
| | m ³ | m ³ | m ³ | h | m ³ | 倍 | h | m ³ | % | m ³ | % | h | kg | mg/l |
| 4月 | 2,000 | 3,026,400 | 30,625 | 4.22 | 11,703 | 4.02 | 7.19 | 1,210,600 | 41.18 | 32,820 | 1.12 | 4.56 | 2,651.9 | 0.87 |
| 5月 | 0 | 3,011,000 | 30,252 | 4.31 | 12,330 | 4.16 | 7.34 | 1,251,600 | 42.10 | 29,418 | 0.99 | 4.65 | 2,602.3 | 0.87 |
| 6月 | 200 | 3,175,500 | 29,787 | 4.06 | 10,730 | 3.57 | 6.89 | 1,206,700 | 39.37 | 25,468 | 0.84 | 4.37 | 2,792.7 | 0.87 |
| 7月 | 100 | 3,337,200 | 30,211 | 3.96 | 11,118 | 3.44 | 6.75 | 1,250,000 | 38.61 | 20,977 | 0.64 | 4.27 | 3,033.6 | 0.88 |
| 8月 | 0 | 2,563,000 | 30,561 | 5.05 | 11,517 | 4.56 | 8.64 | 1,249,100 | 49.42 | 29,526 | 1.17 | 5.48 | 2,277.4 | 0.90 |
| 9月 | 200 | 3,069,300 | 29,715 | 4.50 | 10,548 | 3.62 | 7.16 | 1,208,100 | 40.91 | 21,733 | 0.75 | 4.49 | 2,962.7 | 0.97 |
| 10月 | 0 | 3,122,300 | 31,697 | 4.85 | 11,959 | 3.93 | 7.11 | 1,245,300 | 40.56 | 21,044 | 0.69 | 4.50 | 3,043.1 | 0.98 |
| 11月 | 0 | 2,761,000 | 34,230 | 5.33 | 12,235 | 4.53 | 7.81 | 1,198,200 | 44.28 | 25,575 | 0.95 | 4.89 | 2,359.5 | 0.86 |
| 12月 | 400 | 2,911,300 | 31,864 | 5.24 | 12,364 | 4.36 | 7.66 | 1,250,600 | 43.85 | 25,484 | 0.89 | 4.85 | 2,522.4 | 0.87 |
| 1月 | 0 | 2,683,400 | 32,705 | 5.63 | 13,269 | 5.02 | 8.24 | 1,250,800 | 47.17 | 26,404 | 0.99 | 5.22 | 2,277.4 | 0.86 |
| 2月 | 0 | 2,373,400 | 28,158 | 5.73 | 11,894 | 5.06 | 8.39 | 1,130,600 | 48.05 | 25,222 | 1.08 | 5.32 | 1,997.1 | 0.86 |
| 3月 | 0 | 2,421,700 | 31,214 | 6.24 | 13,788 | 5.77 | 9.15 | 1,244,800 | 52.11 | 32,346 | 1.36 | 5.79 | 2,025.5 | 0.85 |
| 年合計 | 2,900 | 34,455,500 | 371,019 | | 143,455 | | | 14,696,400 | | 316,017 | | | 30,545.6 | |
| 月平均 | 242 | 2,871,292 | 30,918 | 4.93 | 11,955 | 4.34 | 7.69 | 1,224,700 | 43.97 | 26,335 | 0.96 | 4.87 | 2,545.5 | 0.89 |
| 日平均 | 8 | 94,399 | 1,016 | | 393 | | | 40,264 | | 866 | | | 83.7 | |

(2) 汚泥処理実績

| 単位 | 重力濃縮 投入量 (初沈汚泥) | し尿投入量 (着水井投入) | 九電等から の買電量 | 環境工場から の買電量 | 電力 総使用量 |
|-----|-----------------------|------------------|---------------|----------------|------------|
| | m ³ | m ³ | kWh | kWh | kWh |
| 4月 | 71,455 | 1,390 | 0 | 904,280 | 904,280 |
| 5月 | 66,512 | 1,360 | 0 | 921,190 | 921,190 |
| 6月 | 70,457 | 1,510 | 873,510 | 0 | 873,510 |
| 7月 | 68,221 | 1,580 | 571,800 | 285,620 | 857,420 |
| 8月 | 66,841 | 1,400 | 0 | 926,360 | 926,360 |
| 9月 | 65,705 | 1,514 | 0 | 869,180 | 869,180 |
| 10月 | 66,377 | 1,274 | 0 | 893,010 | 893,010 |
| 11月 | 73,830 | 1,580 | 0 | 878,170 | 878,170 |
| 12月 | 69,674 | 1,380 | 0 | 915,240 | 915,240 |
| 1月 | 65,745 | 1,130 | 0 | 926,390 | 926,390 |
| 2月 | 59,598 | 1,580 | 0 | 852,340 | 852,340 |
| 3月 | 62,674 | 1,470 | 0 | 963,070 | 963,070 |
| 年合計 | 807,089 | 17,168 | 1,445,310 | 9,334,850 | 10,780,160 |
| 月平均 | 67,257 | 1,431 | 120,443 | 777,904 | 898,347 |
| 日平均 | 2,211 | 47 | 3,960 | 25,575 | 29,535 |

| 単位 | 上水使用量 |
|-----|----------------|
| | m ³ |
| 4月 | 541 |
| 5月 | 615 |
| 6月 | 562 |
| 7月 | 1,512 |
| 8月 | 655 |
| 9月 | 525 |
| 10月 | 808 |
| 11月 | 901 |
| 12月 | 875 |
| 1月 | 835 |
| 2月 | 876 |
| 3月 | 579 |
| 年合計 | 9,284 |
| 月平均 | 774 |
| 日平均 | 25 |

| 単位 | 汚泥貯留槽 投入量 | | | | | | 混合汚泥量 | | | | |
|-----|----------------|---------|----------|----------------|---------|----------|----------------|---------|----------|---------|----------|
| | 重力濃縮汚泥 | | | 余剰汚泥 | | | m ³ | 濃度 % | 固形分 t | 濃度 % | 固形分 t |
| | m ³ | 濃度 % | 固形分 t | m ³ | 濃度 % | 固形分 t | | | | | |
| 4月 | 9,070 | 4.84 | 312.88 | 41,313 | 0.51 | 150.64 | 50,383 | 0.92 | 463.52 | | |
| 5月 | 7,782 | 3.21 | 205.70 | 36,106 | 0.73 | 215.62 | 43,888 | 0.96 | 421.32 | | |
| 6月 | 7,228 | 2.31 | 145.98 | 33,623 | 0.93 | 274.79 | 40,851 | 1.03 | 420.77 | | |
| 7月 | 6,693 | 1.72 | 108.82 | 30,402 | 0.81 | 232.45 | 37,095 | 0.92 | 341.27 | | |
| 8月 | 11,330 | 1.07 | 115.80 | 38,630 | 0.86 | 318.85 | 49,960 | 0.87 | 434.65 | | |
| 9月 | 8,183 | 2.29 | 153.13 | 30,443 | 0.86 | 213.82 | 38,626 | 0.95 | 366.95 | | |
| 10月 | 7,588 | 3.37 | 179.43 | 26,585 | 0.85 | 158.88 | 34,173 | 0.99 | 338.31 | | |
| 11月 | 7,529 | 1.16 | 133.37 | 28,920 | 0.51 | 227.48 | 36,449 | 0.99 | 360.85 | | |
| 12月 | 9,010 | 2.21 | 244.22 | 32,598 | 0.48 | 192.66 | 41,608 | 1.05 | 436.88 | | |
| 1月 | 8,619 | 3.92 | 265.99 | 32,032 | 0.62 | 156.78 | 40,651 | 1.04 | 422.77 | | |
| 2月 | 8,155 | 4.05 | 248.57 | 32,338 | 0.73 | 176.61 | 40,493 | 1.05 | 425.18 | | |
| 3月 | 9,564 | 4.05 | 282.49 | 41,090 | 0.75 | 224.05 | 50,654 | 1.00 | 506.54 | | |
| 年合計 | 100,751 | | 2,396.38 | 404,080 | | 2,542.63 | 504,831 | | 4,939.01 | | |
| 月平均 | 8,396 | 2.38 | 199.70 | 33,673 | 0.72 | 211.89 | 42,069 | 0.98 | 411.58 | | |
| 日平均 | 276 | | 6.57 | 1,107 | | 6.97 | 1,383 | | 13.53 | | |

| 単位 | 脱水機 | | | | | | | | セメント 原料化 搬出量 t | 汚泥 燃料化 搬出量 t | 環境工場 搬出量 t |
|-----|-----------------------|---------|----------|--------|----------|-----------|----------|----------|-------------------------|-----------------------|------------------|
| | 投入量 m ³ | ポリ鉄使用量 | | 凝集剤注入量 | | ケーキ発生量 | | | | | |
| | | kg | 注入率 % | kg | 注入率 % | t | 含水率 % | 固形分 t | | | |
| 4月 | 50,383 | 88,308 | 15.60 | 3,758 | 0.66 | 1,942.76 | 70.87 | 566.07 | 1,875.29 | 7.31 | 60.16 |
| 5月 | 43,888 | 76,210 | 14.76 | 3,398 | 0.66 | 1,810.66 | 71.49 | 516.23 | 1,793.92 | 0.00 | 16.74 |
| 6月 | 40,851 | 70,825 | 13.89 | 3,389 | 0.66 | 1,737.90 | 70.67 | 509.89 | 1,634.90 | 103.00 | 0.00 |
| 7月 | 37,095 | 64,418 | 15.08 | 2,717 | 0.64 | 1,426.85 | 70.07 | 427.18 | 930.06 | 57.14 | 439.65 |
| 8月 | 49,960 | 88,514 | 18.12 | 3,784 | 0.77 | 1,818.76 | 73.14 | 488.59 | 1,598.20 | 68.82 | 151.74 |
| 9月 | 38,626 | 65,753 | 14.97 | 3,065 | 0.70 | 1,599.35 | 72.55 | 439.13 | 1,372.92 | 226.43 | 0.00 |
| 10月 | 34,173 | 57,408 | 14.52 | 2,729 | 0.69 | 1,432.11 | 72.40 | 395.39 | 1,379.59 | 52.52 | 0.00 |
| 11月 | 36,449 | 62,215 | 14.52 | 2,982 | 0.70 | 1,579.65 | 72.87 | 428.62 | 1,199.75 | 209.11 | 170.79 |
| 12月 | 41,608 | 70,211 | 13.63 | 3,598 | 0.70 | 1,914.35 | 73.09 | 515.24 | 1,783.25 | 96.04 | 35.06 |
| 1月 | 40,651 | 68,124 | 13.53 | 3,464 | 0.69 | 1,858.82 | 72.91 | 503.60 | 1,623.72 | 112.17 | 122.93 |
| 2月 | 40,493 | 68,533 | 13.45 | 3,454 | 0.68 | 1,809.15 | 71.84 | 509.57 | 997.23 | 375.89 | 436.03 |
| 3月 | 50,654 | 86,920 | 14.00 | 4,114 | 0.66 | 2,233.07 | 72.20 | 620.90 | 1,987.22 | 228.04 | 17.81 |
| 年合計 | 504,831 | 867,439 | | 40,452 | | 21,163.43 | | 5,920.42 | 18,176.05 | 1,536.47 | 1,450.91 |
| 月平均 | 42,069 | 72,287 | 14.65 | 3,371 | 0.68 | 1,763.62 | 72.03 | 493.37 | 1,514.67 | 128.04 | 120.91 |
| 日平均 | 1,383 | 2,377 | | 111 | | 57.98 | | 16.22 | 49.80 | 4.21 | 3.98 |